

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF CORINTH WATER DISTRICT)	CASE NO.
FOR A DEVIATION FROM COMMISSION REGULATIONS)	95-418
REGARDING WATER STORAGE)	

O R D E R

By application received September 20, 1995, Corinth Water District ("Corinth Water") requested permission to deviate from 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Corinth Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 134,000 gallons, and its current water storage capacity is 122,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Corinth Water is not in compliance with 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Corinth Water should be given until December 31, 2000 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Corinth Water be and it hereby is given until December 31, 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Corinth Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to December 31, 2000.

Done at Frankfort, Kentucky, this 10th day of October, 1995.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director